



NAPCO, a Westlake company
2801 Post Oak Blvd., Suite 600 ■ Houston, Texas 77056
Tel 713.840.7473 ■ Fax 713.552.0087

Re: Schedule 40 PVC Rigid Conduit Manufactured in Woodbridge, Ontario, Canada Facility

To Whom It May Concern:

1/2" through 6" Schedule 40 Rigid Conduit pipe shall be manufactured in accordance with CSA, ANSI/UL 651 and NEMA TC-2. It shall be manufactured from virgin PVC compound.

Schedule 40 Rigid Conduit pipe shall be certified to the Canadian Standards Association (CSA) standard C22.2 No 211.2 and Underwriters Laboratories (UL) 651, and conforms to NEMA TC-2. Rigid Conduit shall be installed according to the National Electrical Code (NEC) Article 352.

Sincerely,
NAPCO