

MUNICIPAL PRODUCT SPECIFICATION


C900/RJIB Certa-Lok® with Fluid-Tite® Gasket PVC Pressure Pipe Restrained Joint Integral Bell

NAPCO's C900/RJIB Certa-Lok PVC Pressure Pipe is manufactured to meet the demands of today's municipal needs for water and wastewater pressure applications. This unique integral bell restrained joint pipe system is designed for trenchless applications with robust tensile strength for pulling multiple segments underground. The smooth curve at the bell specifically reduces friction and allows for quick and easy assembly without interrupting the pulling process.


A segmented PVC pipe solution, this product reduces the jobsite footprint and minimizes community disruption with a reduced need for jobsite staging area and traffic control. The Fluid-Tite gasket offered in sizes 6" through 16" has a superior sealing surface for a leak-free joint and greater deflection capability.

INSTALLATION METHODS

- Horizontal directional drilling (HDD)
- Static pipe-bursting
- Open-cut
- Carrier pipe inside casings



| Applications | Potable Water | Wastewater | Reclaimed Water | |
|------------------|---|------------|--------------------|--|
| Pipe Color: Blue | | Green | Purple | |
| Certifications: | NSF 14 NSF 61 FM 1612 ^{†*} UL 1285* | None | None | |









| Short Form Specification | | | | | | |
|--------------------------------------|---|--|--|--|--|--|
| Pipe Standard: | C900 | | | | | |
| Diameter Std.: | Cast Iron Outside Diameter (CIOD) | | | | | |
| Nominal Sizes: | 6", 8", 10", 12", 16" | | | | | |
| Dimension Ratios & Pressure Ratings: | DR 25 – 165 psi DR 18 – 235 psi (185 psi)† DR 14 – 305 psi (250 psi)† | | | | | |
| Lay Length: | 10', 20' | | | | | |
| Pipe Compound: | ASTM D1784 Cell Class 12454 | | | | | |
| Pipe Joint Std.: | ASTM D3139 | | | | | |
| Max. Angular Joint Deflection:‡ | 0.5° | | | | | |
| Gasket Standard: | ASTM F477, UL 157 | | | | | |
| Gasket Material Offering: | IR/SBR | | | | | |
| Installation Std.: | AWWA C605 | | | | | |

†FM 1612 calculates pressure ratings differently than AWWA with DR 18 as 185 psi and DR 14 as 250 psi.



^{\$\$}See Installation Guide for more information.

^{*}Excludes 16" nominal size.




C900/RJIB Certa-Lok® with Fluid-Tite® Gasket PVC Pressure Pipe Restrained Joint Integral Bell

| | C900/RJ CERTA-LOK PIPE & COUPLING DIMENSIONS | | | | | | | | | | |
|--------------|--|----|--------------------------------|--------------------------------------|------------------------------|-------|-----------|-------|-------|--------|-------------------|
| | | | Pipe | | | | | | | | |
| Nom. Size | Outside Diameter (OD) | DR | Min. Wall Thickness (T1) | Spigot End Wall Thickness (T2) | Internal Diameter (ID) | X | W | D | P | BOD | Weight (lb/ft) |
| 6" | 6.900 | 18 | 0.383 | 0.513 | 6.134 | 3.000 | 0.500 | 0.145 | 0.271 | 7.816 | 5.3 |
| 0 | | 14 | 0.493 | 0.661 | 5.914 | | | | | 8.030 | 6.6 |
| 8" | 9.050 | 18 | 0.503 | 0.674 | 8.044 | 3.163 | 0.500 | 0.145 | 0.634 | 10.262 | 9.1 |
| 0 | | 14 | 0.646 | 0.866 | 7.758 | | | | | 10.542 | 11.5 |
| 10" | 11.100 | 18 | 0.617 | 0.890 | 9.866 | 3.625 | 0.750 | 0.215 | 0.634 | 12.781 | 13.7 |
| 10" | | 14 | 0.793 | 1.105 | 9.514 | | 0.750 | | | 13.177 | 17.3 |
| 12" | 13.200 | 18 | 0.733 | 1.085 | 11.734 | 3.625 | 0.750 | 0.215 | 0.634 | 15.247 | 19.4 |
| 12 | | 14 | 0.943 | 1.325 | 11.314 | | | | | 15.681 | 24.5 |
| 16" | 17.400 | 25 | 0.696 | 0.884 | 16.008 | 3.673 | 0.875 0.2 | 0.075 | 0.634 | 19.261 | 23.3 |
| 10" | | 18 | 0.967 | 1.205 | 15.466 | | | 0.265 | | 19.881 | 31.9 |

Notes:

- 1. These dimensions are for estimating purposes only. All dimensions are in inches unless otherwise specified.
- 2. DR = Dimension Ratio
- 3. AWWA Pressure Class @ 73°F and includes 2:1 safety factor.
- 4. Maximum Pull Force based on actual testing and includes 2:1 safety factor.
- 5. Internal diameter calculated using nominal outside diameter and minimum wall thickness.
- 6. Additional wall thickness provides additional joint strength in machined areas. This has been calculated to have a negligible effect on flow performance.
- 7. Contact NAPCO Technical Services for assistance with mandrel sizing.
- 8.16" nominal size is not listed to UL 1285 or FM 1612.

| JOINT PERFORMANCE DATA | | | | | | | |
|------------------------|----|----------------------------|-----------------------------|-----------------------------|--|--|--|
| Nom. Size | DR | Pressure Class (psi) | Min. Bend Radius (ft) | Max. Pull Force (lbf) | | | |
| 6" | 18 | 235 | 1.1.1 | 20,100 | | | |
| 0 | 14 | 305 | 144 | 22,300 | | | |
| 8" | 18 | 235 | 188 | 27,500 | | | |
| 0 | 14 | 305 | 100 | 31,000 | | | |
| 10" | 18 | 235 | 232 | 49,500 | | | |
| 10 | 14 | 305 | 232 | 52,600 | | | |
| 12" | 18 | 235 | 275 | 60,000 | | | |
| 12 | 14 | 305 | 213 | 60,000 | | | |
| 16" | 25 | 165 | 363 | 68,500 | | | |
| 10 | 18 | 235 | 303 | 72,000 | | | |









C900/RJIB Certa-Lok® with Fluid-Tite® Gasket PVC Pressure PipeRestrained Joint Integral Bell

| C900/RJIB CERTA-LOK ACCESSORIES | | | | | | | | | | |
|---------------------------------|--------------|-----------------|-------------|--------|----------------|----------|---------|----------------|--|--|
| = | Nom. Size | Splines Splines | | | | Gaskets | | | | |
| Application | | Material | Size | Length | Part Number | Material | Shape | Part Number | | |
| | 6" | Nylon | 0.250x0.375 | 24 | S0624TN0 | IR/SBR | Profile | GSPR000600 | | |
| lard | 8" | Nylon | 0.250x0.375 | 32 | S0832TN0 | IR/SBR | Profile | GSPR000800 | | |
| Standard | 10" | Nylon | 0.375x0.625 | 39 | S1039TN0 | IR/SBR | Profile | GSPR001000 | | |
| 0, | 12" | Nylon | 0.375x0.625 | 46 | S1246TN0 | IR/SBR | Profile | GSPR001200 | | |
| | 16" | Nylon | 0.500x0.750 | 60 | S1660TN0 | IR/SBR | Profile | GSPR001600 | | |

Some or all of these products are protected by patents. Visit www.napcopipe.com/patents for more information.

