

March 12, 2012

Re: Gasketed Sewer Pipe Manufactured in Newbern, TN Facility

To Whom It May Concern:

4" through 15" gasketed SDR 35 and SDR 26 sewer pipe shall be manufactured in accordance with ASTM D3034. It shall be manufactured from virgin PVC compound having a cell classification of 12364 in accordance with and certified by the National Sanitation Foundation (NSF) to meet ASTM D1784. Gaskets shall be manufactured in accordance with ASTM F477 or ASTM F913. Gasket joints must comply with ASTM D3212 Internal Pressure Test (exfiltration) and Vacuum Test (infiltration) at 5 degrees of gasket joint deflection with an internal hydrostatic pressure rating of 10.8 psi.

Gasketed SDR 35 and SDR 26 sewer pipe shall be certified by the International Sanitation Foundation (NSF).

Sincerely,



Jon Houghton  
President  
Royal Building Products - Shelby